

County of Tehama  
Department of Environmental Health  
633 Washington St., Rm 36  
Red Bluff CA 96080  
Phone # (530) 527-8020  
www.co.tehama.ca.us

## OFFICIAL FOOD INSPECTION REPORT



Tim Potanovic, REHS - Director

Facility Name	: MCDONALD'S	Owner	: MJROBIK, INC
Site Address	: 215 ANTELOPE BLVD	Owner Address	: 871 MISSILE TOE LN
Facility ID	: FA0000589	Inspector	: EE0000005 - Tia Branton
Record ID	: PR0000209	Inspector Phone	: (530) 527-8020
License/Permit Number	: 2191-16F-1	Program:	: 1624 - Restaurant 2000 Sq.
Person in Charge	:		: Feet-6000 Sq. Feet
Inspection Date	: 4/29/2020	Total Inspection Time	: 45 min.
Inspection Number	: DA0007580	Result	: 05 - Reinspection Required
Purpose of Inspection	: 003 - Complaint Inspection		

An inspection of your property revealed the following violations. Please note the date for reinspection. Thank you for your cooperation.

### Inspection Violations

#### ALL VENTILATION SHALL MEET REQUIREMENTS - 16 38B

"Comply by Date" Not  
Specified

Not In Compliance

#### Violation Description:

Exhaust hoods shall be provided to remove toxic gases, heat, grease, vapors and smoke and be approved by the local building department. Canopy-type hoods shall extend 6# beyond all cooking equipment. All areas shall have sufficient ventilation to facilitate proper food storage. Toilet rooms shall be vented to the outside air by a screened openable window, an air shaft, or a light-switch activated exhaust fan, consistent with local building codes. (114149, 114149.1)

#### Corrective Description:

#### Inspector Comments:

Ventilation not working correctly. Kitchen filled with smoke. Spoke with Jacob about repairs...Should be completed by Friday. Conditions inside kitchen shall be addressed until repairs complete.

### Overall Inspection Comments

Received By:

Date

Tia Branton

Date