

County of Tehama
Department of Environmental Health
633 Washington St., Rm 36
Red Bluff CA 96080
Phone # (530) 527-8020
www.co.tehama.ca.us

OFFICIAL FOOD INSPECTION REPORT



Tim Potanovic, REHS - Director

Facility Name	: Vina Elementary School	Owner	: Los Molinos Unified School District
Site Address	: 4790 D St	Owner Address	: 7851 HIGHWAY 99E
Facility ID	: FA0000839	Inspector	: EE0000004 - Don Shelvock
Record ID	: PR0000701	Inspector Phone	: Not Specified
License/Permit Number	: 5282-16F-1	Program:	: 1635 - School Cafeteria/Senior
Person in Charge	:		: Program
Inspection Date	: 5/18/2016	Total Inspection Time	: 30 min.
Inspection Number	: DA0003977	Result	: 03 - Minor Violations
Purpose of Inspection	: 102 - Routine Inspection		

An inspection of your property revealed the following violations. Please note the date for reinspection. Thank you for your cooperation.

Inspection Violations

PROPER BACKFLOW PROTECTION - 16 41

"Comply by Date" Not
Specified

Not In Compliance

Violation Description:

The potable water supply shall be protected with a backflow or back siphonage protection device, as required by applicable plumbing codes. (114192) All plumbing and plumbing fixtures shall be installed in compliance with local plumbing ordinances, shall be maintained so as to prevent any contamination, and shall be kept clean, fully operative, and in good repair. Any hose used for conveying potable water shall be of approved materials, labeled, properly stored, and used for no other purpose. (114171, 114189.1, 114190, 114193, 114193.1, 114199, 114201, 114269)

Corrective Description:

Inspector Comments:

The janitorial sink must have a backflow vacuum breaker.

Overall Inspection Comments

Received By:

Date

Don Shelvock

Date